

MARIANO MARCOS STATE UNIVERSITY

Bids and Awards Committee

BID BULLETIN No. 2022-022

Project: Establishment and/or Support to the College of Medicine (CO Component: COM Laboratory Building), MMSU-COM, City of Batac, Ilocos Norte

ABC: P38,997,548.04

Issued pursuant to Sec. 22.5 of the IRR of R.A. 9184 to clarify and/or amend certain provisions in the Bidding Documents issued for the above project:

A. AMENDMENTS/INCLUSIONS

Reference	Amendments/Inclusions
ITB Clause 5.2	For this purpose, contracts similar to the Project refer to contracts which have the same major categories of work which shall be: Earthworks, plain and reinforced concrete, finishing works, plumbing works, electrical works, Automatic Fire sprinkler system, fire alarm system and installation of exhaust ventilation system and medical laboratory in a college of medicine building and medical facility in a hospital setting. The contractor must have completed similar project of medicine laboratory/facility as previously described.
ITB Clause 5.5	For the Single Largest Completed Contract (SLCC), the supporting documents shall be the Certificate of Acceptance or the Construction Performance Evaluation System (CPES) for government projects. For private contracts, the equivalent document to be accepted is the Certificate of Completion or Acceptance.
ITB Clause 10.4	Construction Foreman general experience reduced to at least 5 years
Specifications B.2, Reinforcing Steel	All reinforcing bars are Grade 40
Specifications C.17 & C.18	Rooms with acoustic board ceiling shall be TB DOTS Nurse area and waiting area. Laboratory room releasing, bacteriology and chemical chemistry. Extraction and pathology area. Radiology room office and ante room. The rest shall be hardiflex board on metal furring frame. Electrical Room and Utility Room has no ceiling. (See reflected ceiling plan)
Specifications C.20, Granite Tiles	Roofdeck is not included





MARIANO MARCOS STATE UNIVERSITY

Bids and Awards Committee

Specifications C.21, Water	Areas included are second floor comfort room, canopy at
Proofings and cement	front and western exit balcony. The minimum number of
base	coats is two but subject for flood testing.
Specifications, ceiling works	Ceiling shall be 4.5mm thk hardiflex board with
	19mmx50mm Furring Channel spaced at 0.40m on
	center and 12mmx38mm Carrying Channel spaced at
	1.20m on center. For 60cmx60cm Acoustic Boards,
	ceiling shall be on Exposed Grid (T-runner) ceiling
	system. (See reflected ceiling plan)
C.13 Metal Structures	Metal structure is removed
C.23 Water Source	Booster Pump and centrifugal pump is removed. Water
	supply shall be deep well with 2HP Jet pump and 82 gals
	pressure tank with complete accessories.
C.24 Plumbing Fixtures	4000 liters water tank is removed.
Detailed Estimated format	Detailed estimate shall be in DUPA format

For the guidance and information of all concerned.

June 27, 2022.

NATHANIEL R. ALIBU BAC Chair





